

#### **CITY OF WASHINGTON, ILLINOIS Committee of the Whole Agenda Communication**

Meeting Date: November 11, 2024

**Prepared By:** Dennis Carr – City Engineer

Brian Rittenhouse – Public Works Director

**Agenda Item:** Presentation – Water System Improvement Projects

**Explanation:** As discussed at the March 11<sup>th</sup> Committee of the Whole and the March 18<sup>th</sup> City Council

meetings, the IEPA requires a Project Plan in order to obtain a State Revolving Fund (SRF) Loan. The Project Plan will need to include a rate study to show how the City will afford to pay the loan payment. The rate study will develop a financial plan for the utility and needs to

consider future capital improvement costs.

Staff has been working with Crawford Murphy and Tilly (CMT) to identify future capital improvements to the City's water systems. The attached presentation discuses several improvement projects that were identified for Council to consider. The approved projects will

be included in the rate study.

Fiscal Impact: TBD

Staff's Recommendation: Staff recommends discussion to determine which projects Council wishes to

include in the rate study.

**Action Requested:** Discussion and Direction

Water System Improvement Projects

City of Washington, IL

Committee of the Whole

November 11, 2024








## Existing Water System Assets



2 Water Treatment Plants



2 Water Towers450,000 gallons each



## Water Distribution Pipe Network

- ~85 miles of watermain ranging in size from 4" – 16"
- ~5,400 customers






# Overview of Projects

- Water Tower #3
- Well #13
- Route 24 Watermain Relocation
- Southeast Area Watermain Improvements
- Sunnyland Water Service Redundancy
- Bondurant Street Watermain Replacement



### Water Tower #3



#### **Need for Project:**

- City does not meet ISO fire flow recommendation of having a minimum storage equal to the highest flow for 3 hours
  - Tower #2 Capacity = 450,000 gallons
  - City's highest flow = 3,500 gpm which equals 630,000 total gallons for a 3 hour period
- City does not meet IEPA Title 35 minimum storage recommendation for systems not providing fire protection – minimum system storage should equal daily consumption
  - City's Average Daily Consumption = 1.1 MGD
  - City's System Storage = 0.9 MGD

#### **Project Design:**

- 500,000 gallon elevated spheroid shaped tank
- 1,427 lineal feet of new 12" diameter watermain along Cummings Lane

#### **Estimated Project Construction Cost:**

- Water Tower \$4,300,000
- Cummings Lane Watermain \$530,000



## Well #13



#### **Need for Project:**

- Water Treatment Plant #2 is primarily served by Wells #11 and #12 located at the Washington Public Works building off Legion Road
- In an emergency, the Plant can run off wells #9 and #10 located near the Plant. However, the water chemistry of this aquifer location is very high in ammonia. Current plant operations are illequipped to remove excess ammonia.
- Increase the treatment capacity at Water Treatment Plant #2 from 1.5 MGD to 2.0 MGD
- Proposed Well #13 is a better suited alternative for a redundant, emergency well

#### **Project Design:**

- Submersible well pump located 424 feet deep by an 8" diameter steel column
- ~20 foot x 15 foot block building
- Connected to existing 16" raw water line running to Water Treatment Plant #2

#### **Estimated Project Construction Cost:**

• \$1,500,000





## Route 24 Watermain Relocation

#### Need for Project:

- Accommodate future IDOT roadway improvements from Legion Road to Lynn Street
- Critical Watermain Location = Wilmor Road to Lynn Street

#### **Project Design:**

- Relocate ~20,050 lineal feet of 6" 10" watermain to outside pavement limits
- ~180 service connections
- 38 connections to existing watermains

#### **Estimated Project Construction Cost:**

Total Length - \$7,730,000 Critical Length - \$4,500,000



## Southeast Area Watermain Improvements

#### **Need for Project:**


- Aging infrastructure of cast iron piping pasted its life expectancy
- Cast iron water mains account for 1/3 of the system but represent an average of 2/3 of the breaks
- Oldest watermain in the system is over 100 years old

#### Project Design:

- ~17,000 lineal feet of 4" diameter watermain replacement
- ~286 service connections

#### **Estimated Project Construction Cost:**

• \$8,870,000 (Split into multiple projects over 20 years)





## Sunnyland Water Service Redundancy

#### **Need for Project:**


- Currently, a single existing 10" watermain serves Sunnyland
- Any failure of that line would leave Sunnyland with no access to water
- Connecting the existing 8" diameter watermain lines to the North of Sunnyland allows for redundancy in serving those residents

#### **Project Design:**


• ~4,100 lineal feet of new 8" diameter watermain along School Street and Centennial Drive

#### **Estimated Project Construction Cost:**

\$875,000







## Bondurant Street Watermain Replacement

#### **Need for Project:**

 Aging infrastructure of existing watermain serving critical facility – Washington High School

#### Project Design:

 Replace ~ 670 lineal feet of 4" watermain with new 8" watermain

#### **Estimated Project Construction Cost:**

• \$375,000



## Potential Funding Sources



City of Washington Water Revenue



IEPA State Revolving Fund Loan Program



Utility Revenue Bonds or Municipal Bonds



## Next Steps







## Questions

